

CERTIFICAT

CERTIFICADO

СЕРТИФИКАТ

認證證書

CERTIFICATE

ZERTIFIKAT



Italia

# CERTIFICATE

according to IEC EN 61508

Certificate No.: TUV IT 24 SIL 0349

**CERTIFICATE OWNER:** Chaoda Valves Group Co., Ltd.  
*Registered Address:* Jiangbei Street, Oubei, Yongjia,  
PC: 325105, Zhejiang Province, P. R. China  
*Manufacturing Address:* Wuxing Industry Zone, Oubei,  
Yongjia, PC: 325105, Zhejiang Province, P. R. China

**WE HEREWITH CONFIRM THAT**  
**CD SERIES TRUNNION BALL VALVES**  
**MEET THE SIL REQUIREMENTS DETAILED IN THE ANNEXED TABLE**  
**FOR THE SAFETY FUNCTIONS:**

***SIF1: “correct switching on demand (open to closed) and tight for closing phase,  
in low demand mode of operation”***

***SIF2: “correct switching on demand (closed to open), in low demand mode of  
operation”***

**Examination result:** The above reported CD Series Trunnion Ball Valves  
were found to meet the standard defined requirements  
of the safety levels detailed in the following table  
according to IEC EN 61508, under fulfillment of the  
conditions listed in the Report R TUV IT 24 SIL 0319, on  
which this Certificate is based

**Examination parameters:** Construction/Functional characteristics and reliability  
and availability parameters of the above mentioned CD  
Series Trunnion Ball Valves

**Official Report No.:** R TUV IT 24 SIL 0319

**Expiry Date** February, 22<sup>nd</sup> 2027

**THE PRESENT DOCUMENT SUBSTITUTES AND REPEALS THE DOCUMENT C-IS-722233004-01**

**Reference Standard** IEC EN 61508:2010 Part 2, 4, 6, 7

**Milan, February, 23<sup>rd</sup> 2024**

TÜV ITALIA Srl



TÜV ITALIA Srl

Industrie Service Division  
Managing Director

Alberto Carelli



SUMMARY TABLE



E/EE/EP safety-related system (final element)	CD Series Trunnion Ball Valves produced by Chaoda Valves Group Co., Ltd.	
System type	Type A	
Systematic Capability	SC3	
Safety Function Definition	SIF1: “Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation”	SIF2: “Correct switching on demand (closed to open), in low demand mode of operation”
Max SIL <sup>(1)</sup>	SIL3	SIL3
λ <sub>TOT</sub>	2,909E-09	2,909E-09
λ <sub>NE</sub>	6,961E-10	9,953E-10
λ <sub>S</sub>	0,000E+00	0,000E+00
λ <sub>DD,PST</sub> <sup>(2)</sup>	5,903E-10	1,409E-09
λ <sub>DU,FPT</sub>	1,623E-09	5,054E-10
β and β <sub>D</sub> factor	10%	10%
MRT	8 h	8 h
Hardware Safety Integrity	Route 2 <sub>H</sub>	Route 2 <sub>H</sub>
Systematic Safety Integrity	Route 2 <sub>S</sub>	Route 2 <sub>S</sub>
<b>Remarks</b>  (1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD <sub>AVG</sub> considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements.  (2) Considering an automatic Partial Stroke Test.		

SIL classification according to Standard IEC EN 61508:2010 CD Series Trunnion Ball Valves produced by Chaoda Valves Group Co., Ltd.

NOTE: The present table is integral part of the Document TUV IT 24 SIL 0349  
Date: February, 23<sup>rd</sup> 2024